



COLORADO

Department of Local Affairs

Division of Housing

Multi-family Housing Rehabilitation Standards

Effective October 2016

Colorado Department of Local Affairs
Division of Housing
1313 Sherman Street, Room 500
Denver, Colorado 80203
(303) 864-7810
<http://dola.colorado.gov/doh>

Alison George, Director

Multi-Family Housing Rehabilitation Standards

Description:

The Division of Housing (DOH) has created these Multi Family Housing Rehabilitation Standards (Rehab Standards) to uniformly provide for safe, decent, durable, high-performing and affordable housing. They apply to multi-family properties rehabilitated with the use of DOH funding. Further, these standards are written to comply with the requirements of the HOME Investment Partnership Program (HOME) and the National Housing Trust Fund (HTF) and address the following:

- Capital Needs Assessment (found on page 3 in Establishing Scope of Work Priorities)
- Accessibility (found on Page 4 in Applicable Laws and Regulations)
- Disaster mitigation (found on Page 5 in Applicable Laws and Regulations)
- State and local codes (found on Page 5 in Applicable Laws and Regulations)
- Uniform Physical Condition Standards (found on Page 5 in Applicable Laws and Regulations)
- Health and safety (Section 1)
- Lead-based paint (Section 1)
- Major systems (Section 2 thru 11)

These standards are designed to be used with multi-family properties with five or more units. The Single-family Housing Rehabilitation Standards apply to one- to four- unit dwellings of three stories or less.

These standards describe the minimum requirements in a variety of ways including:

- These standards are designed to exceed the Uniform Physical Condition Standards (UPCS) and ensure upon completion, the assisted project and units will be decent, safe, sanitary and in good repair as described in 24 CFR 5.703. Appendix A: Uniform Physical Condition Standards for Multifamily Housing Rehabilitation identifies, at a minimum, those items that must be inspected along with the observable deficiency and the type and degree of deficiency that must be addressed. Any deficiency found to exist from Appendix A must be addressed, even if a specific standard for that item is not included in this document. In the event that a specific standard is not included for an observed deficiency, the repair shall be completed in a thorough and workmanlike manner in accordance with industry practice.
- Minimum requirements for the materials and methods used. **All construction materials and methods shall be in compliance with locally adopted building codes.** If there are no local codes, then they shall comply with State Code (the National Electrical Code (NEC), 2014 Edition, as may be amended by the Colorado Electrical Board, the International Plumbing Code (IPC) 2015 and the International Fire/Gas Code (IFGC) as amended in the Colorado Plumbing Code, and the International Existing Building Code of the ICC (IEBC)).

Note: At the time of publication and adoption of these standards, the adopted codes

referenced are believed to be those in force. As standards and codes change and are put into effect by the governing authorities having jurisdiction, the new standards and codes will apply in lieu of those referenced.

- The requirements of regulatory agencies such as the local government’s Building, Housing and Zoning Codes; the Environmental Protection Agency (EPA); federal, state and local Historic Preservation requirements. **These Rehabilitation Standards are not meant to substitute for a thorough understanding of all of the codes and regulations that may apply to your projects.**
- The requirements of funders such as HUD (CDBG, HOME, NSP, HTF, CDBG-DR) or local governments, including the Environmental Review process.

In order to access further and more detailed information, hyperlinks to useful web sites are included in this document. They can serve as a valuable resource.

Establishing Scope of Work Priorities:

For all Rehabilitation Projects, health and safety standards represent the highest priority work to be completed first, especially if they are life threatening. Any and all life threatening health and safety deficiencies shall be corrected in every rehabilitation project, regardless of funding source **and must be addressed immediately if the housing is occupied.** Appendix A identifies life-threatening deficiencies in (****bold italic***) for the property site, building exterior, building systems, common areas, and units.

Another top priority for the scope of work is the remaining useful life of all major building systems, which shall be estimated through a Capital Needs Assessment (CNA) or other means and must cover the period of affordability. Federal funding requirements dictate that if a multifamily housing project consists of 26 units or more, a (CNA) shall be performed to determine the remaining useful life of major systems, and the Division of Housing (DOH) may require a (CNA) regardless of project size. Those systems that are found to be at or near the end of their useful life shall be repaired or replaced as part of the rehabilitation of the project. A replacement reserve shall be established and monthly payments made to the reserve account in an amount adequate to repair or replace systems as needed through the entire period of affordability. Major systems include the structure, roof, cladding, weatherproofing (windows, doors, siding, gutters, etc.), plumbing, electrical, heating, ventilation, and air conditioning, and are identified by the symbol “[**MAJOR SYSTEM**]”.

The next priority for inclusion in the scope of work is any violation of locally adopted building code, housing code, zoning ordinance, and/or disaster mitigation standards. It is important for Grantees and their Contractors/Subcontractors to be knowledgeable about their local codes, and to communicate freely with local code officials if their code requirements are unclear. If there are no locally adopted building codes, then State Code (the National Electrical Code (NEC), 2014 Edition, as may be amended by the Colorado Electrical Board, the International Plumbing Code (IPC) 2015 and the International Fire/Gas Code (IFGC) as amended in the

Colorado Plumbing Code, and the International Existing Building Code of the ICC (IEBC)).

Most building codes, including the International Existing Building Code of the ICC (IEBC), allow for building components that were constructed in compliance with the building code that was in effect at the time, and that do not pose a health or safety threat, to remain as is. Generally, they do not need to be improved to meet current code unless they are a threat to health or safety. The same applies to these Rehab Standards – if a building component is not a threat to health or safety, and if it complies with the building code that was in effect when it was built, then the component does not need to be brought into compliance with these standards.

Grantees may choose to implement “Green Standards,” identified by this symbol - **[GREEN STANDARD]**, unless they are found under health and safety, in which case they shall be corrected to the GREEN STANDARD. These standards accomplish one or more of the following:

- Conserve water
- Conserve energy
- Provide residents with a healthier living environment
- Reduce impact on the natural environment
- Create a more sustainable product lifetime

In areas where the **[GREEN STANDARD]** is optional and a Grantee chooses not to implement the GREEN STANDARD, the repair or replacement shall be completed according to applicable codes and in accordance with industry standards.

Source Documents:

The standards in this document were adapted from a template used by Livable Housing, Inc., a consulting and training firm, and were based on a number of similar documents used in various housing rehabilitation programs. The standards with the label **[GREEN STANDARD]** were added with the assistance of Enterprise Community Partners and intended to be used for including green rehabilitation improvements that follow accepted national green building standards such as LEED and the Green Communities Criteria.

Applicable Laws and Regulations

These Rehabilitation Standards are not meant to substitute for a thorough understanding of all of the regulations that may apply to your projects.

The following statutory and regulatory requirements are applicable to projects funded with federal funds:

- HUD – HOME, HTF or CDBG regulations (depending on the funding source used)
- Accessibility Requirements in 24 CFR part 8, which implements Section 504 of the Rehabilitation Act of 1973 (29 U.S.C. 794), and Titles II and III of the Americans with Disabilities Act (42 U.S.C. 12131 – 12189) Implemented at 28 CFR parts 35 and 36, as

applicable. Covered multifamily dwellings, as defined at 24 CFR 100.201 shall also meet the construction requirements at 24 CFR 100.205.

- NEPA Environmental Review
- Local Code: Current locally adopted Building, Housing and Zoning Codes, including any local Disaster Mitigation Standards.
- If no local Building Code: State Code (the National Electrical Code (NEC), 2014 Edition, as may be amended by the Colorado Electrical Board, the International Plumbing Code (IPC) 2015 and the International Fire/Gas Code (IFGC) as amended in the Colorado Plumbing Code, and the International Existing Building Code of the ICC (IEBC)).
- Federal Code: For programs funded with HOME or HTF funds after January 24, 2014, HUD will adapt the Uniform Physical Condition Standards (UPCS) inspection protocol for housing rehabilitation.
- Environmental Protection Agency (EPA) regulations including the RRP regulations for Lead Based Paint
- EPA regulations for the Resource Conservation and Recovery Act (RCRA), dealing with hazardous materials.
- If the building is over 50 years old, then the Colorado State Historic Preservation Office (SHPO) requirements as well as any federal or local Historic Preservation requirements.
- Life Safety Code – NFPA 101 as published by the National Fire Protection Association.

The following are additional guidelines and codes that may apply:

- Energy: A locally adopted energy code, 2009 (or newer) International Energy Conservation Code (IECC).
- Accessibility: ANSI standards for accessibility by disabled residents
- HAZMAT: HUD Guidelines for the Evaluation and Control of Lead-Based Paint Hazards in Housing

TABLE OF CONTENTS

	<u>Page</u>
1) Health and Safety	8
a. Contaminants	
b. Lead Based Paint (LBP)	
c. Asbestos	
d. Radon	
e. Mold	
f. Fire Safety – Egress	
g. Fire and CO Alarms	
2) Site	11
a. Drainage	
b. Outbuildings	
c. Fencing and Gates	
d. Paving and Walks	
e. Trees and Shrubbery	
f. Lawn	
3) Building Exterior	14
a. Exterior Cladding	
b. Exterior Porches	
c. Exterior Railings	
d. Exterior Steps and Decks	
4) Foundation and Structure	15
a. Firewalls	
b. Foundations	
c. Structural Walls	
5) Windows and Doors	16
a. Interior Doors	
b. Exterior Doors	
c. Windows	
d. Basement Windows	

6) Roofing	18
a. Flat and Low-Slope Roofing	
b. Pitched Roofs	
c. Gutters and Downspouts	
7) Insulation and Ventilation	19
a. Infiltration	
b. Insulation	
c. Bath Ventilation	
d. Kitchen Ventilation	
e. Roof Ventilation	
8) Interior Standards	21
a. Interior Walls and Ceilings	
b. Flooring	
c. Closets	
d. Cabinets and Countertop	
e. Appliances	
9) Electric	23
a. Lighting	
b. Interior Electric Distribution	
c. Service and Panel	
10) Plumbing	25
a. Drain, Waste Vent Lines	
b. Plumbing Fixtures	
c. Plumbing Minimum Equipment	
d. Water Heaters	
e. Water Supply	
11) HVAC	27
a. Air Conditioning	
b. Chimney	
c. Distribution System	
d. Heating	

Appendix A: Uniform Physical Condition Standards for Multifamily Housing

1) Health and Safety

[GREEN STANDARD] is mandatory in this section

Contaminants [GREEN STANDARD]	
Repair Standard	
N/A	
Replacement Standard	
<p>All materials installed shall meet the following standards to minimize the presence of Volatile Organic Compounds (VOC) and Formaldehyde:</p> <ul style="list-style-type: none"> • All paints and primers should meet the most recent Green Seal G-11 Environmental Standard. http://www.greenseal.org/Home.aspx • All particleboard components shall meet ANSI A208.1 for formaldehyde emission limits, or all exposed particleboard edges shall be sealed with a low-VOC sealant or have a factory-applied, low-VOC sealant prior to installation. All MDF edges shall meet ANSI A208.2 for formaldehyde emission limits, or all exposed MDF edges shall be sealed with a low-VOC sealant or have a factory-applied, low-VOC sealant prior to installation. 	

Lead-Based Paint (LBP) [GREEN STANDARD]	
Repair Standard (“Interim Controls”)	
<p>For all housing units constructed prior to 1978, they must meet the lead-based paint requirements at 24 CFR part 35 and must follow HUD LBP Guidelines including testing for LBP and Lead-safe work practices. Only EPA-certified Renovation, Repair and Painting (RRP) contractors may perform the work. See: http://www.hud.gov/offices/lead/lbp/hudguidelines/ All interim controls shall be performed as follows and by properly trained workers:</p> <ul style="list-style-type: none"> • When any LBP-coated surfaces are disturbed, the work area shall be sealed and tenants of occupied buildings shall be adequately protected from LBP hazards. • Occupants may be temporarily relocated as required by the regulations. • All surfaces coated with LBP shall be properly maintained over the life of the program covenants. • Tenants living in buildings constructed prior to 1978 that are not certified as being “lead free” shall be provided with the “Protect Your Family from Lead in Your Home” pamphlet, the location and condition of known LBP, and advance written notice prior to any lead-hazard reduction activity. 	
Replacement Standard (“Abatement”)	
When Interim Control is impractical, the most affordable solution for abatement of the component shall be chosen. For example, walls containing LBP may be covered with drywall or	

guttered and replaced with drywall. Trim and other wood or metal components containing LBP may be removed and replaced with similar materials.

Any work must meet the lead-based paint requirement at 24 CFR par 35 and must follow HUD LBP Guidelines including Lead-safe work practices, and only use EPA-certified abatement contractors to perform the work. See: <http://www.hud.gov/offices/lead/lbp/hudguidelines/>

Asbestos [GREEN STANDARD]

Repair Standard

Asbestos can be found in these and many other common building materials: Ceiling textures, vinyl floor coverings and mastic, boiler and pipe insulation, heating and cooling duct insulation, ceiling tile, roofing products, clapboard shingles, etc. An asbestos inspection by a certified asbestos building inspector is required in Colorado if the trigger level of suspect materials to be disturbed is exceeded. An exemption is possible only if it can be shown that the building was constructed after October 12, 1988 **and** either no asbestos containing material (ACM) was specified in any construction document for the building OR no ACMs were used in the building.

For more information and repair requirements, see the Colorado Dept. of Public Health and Environment's Asbestos website at: <http://www.colorado.gov/cs/Satellite/CDPHE-AP/CBON/1251594599613>

Replacement Standard

Abatement of friable asbestos-containing materials in Colorado shall be performed by a General Abatement Contractor, certified by the Colorado Dept. of Public Health and Environment's Air Pollution Control Division.

For more information and abatement requirements, see the Colorado Dept. of Public Health and Environment's Asbestos website at: <http://www.colorado.gov/cs/Satellite/CDPHE-AP/CBON/1251594599613>

Radon [GREEN STANDARD]

Repair Standard

All residential buildings shall be subject to a "Short Term" Radon Test. If the result is a reading of 4 pCi/L or higher, then perform a follow-up "Short Term" test and average the results. If the average is above 4 pCi/L, remediation shall be required.

Radon test kits may be purchased from your local home improvement store. Be sure the kit says "certified by the [National Radon Proficiency Program](#)." Individuals can also get coupons for mail-order test kits on the Colorado Dept. of Public Health and Environment's website: <http://www.colorado.gov/cs/Satellite/CDPHE-HM/CBON/1251617274212>

Replacement Standard

If, as a result of the testing above, there is a presence of Radon at or above the 4 pCi/L level, remediation shall be undertaken per the EPA guidance in their Consumer's Guide to Radon Reduction: <Http://www.epa.gov/radon/pubs/consguid.html>.

If the home's water comes from a private well, the water should also be tested. Water testing is available from the [Colorado Department of Public Health and Environment's Laboratory Services Division](#).

Mold [GREEN STANDARD]

Repair Standard

Any presence of mold is unacceptable and shall be addressed per the National Center for Healthy Housing protocol "Creating a Healthy Home." Once the source of the mold causing moisture has been identified and repaired, All carpeting, drywall or other gypsum-based wall coverings or any other non-structural components with mold present shall be removed and replaced.

Replacement Standard

U.S. Environmental Protection Agency (EPA) and the U.S. Centers for Disease Control and Prevention (CDC) recommend that trained mold remediation professionals do the mold clean up if mold growth covers more than 100 square feet, or a 10 foot by 10 foot area.

All carpeting, drywall or other gypsum-based wall coverings or any other non-structural components with mold present shall be removed and replaced. The National Center for Healthy Housing protocol "Creating a Healthy Home" shall be followed for remediation of structural components:

http://www.nchh.org/Portals/0/Contents/FloodCleanupGuide_screen_.pdf

Fire Safety - Egress	
Repair Standard	
N/A	
Replacement Standard	
Egress windows are required in all new sleeping and living areas unless other secondary means of escape requirements are met, in accordance with local building codes or the IEBC. No bedrooms shall be created in attics or basements unless Life Safety Code (NFPA 101) egress requirements are met.	

Fire and CO Alarms [GREEN STANDARD]	
Repair Standard	
Existing fire and smoke, carbon monoxide and security systems that meet current local code (or the IEBC) and Colorado State Statute, shall be repaired to operating condition. If hard wiring of smoke detectors is not feasible, then detectors with 10 year lithium batteries may be used.	
Replacement Standard	
Smoke and carbon monoxide detectors shall be installed to meet current local code (or the IEBC) and in accordance with Colorado Statute. If hard wiring of smoke detectors is not feasible, then detectors with 10 year lithium batteries may be used.	

2) Site

Drainage [GREEN STANDARD]	
Repair Standard	
All grading or impervious surfaces adjacent to the building and for a distance of at least 10 feet away from the building shall slope away from the structure at a pitch of at least 1 inch per foot. Sidewalks used for access cannot have a cross slope more than ¼” per foot. Holes or depressions of more than six inches (6”) in diameter should be filled to correct drainage problems and remove safety hazards. All bare earth within three feet of the foundation shall be planted with low-water landscaping. Bare earth more than three feet from the foundation may be reseeded with grass or planted with low-water landscaping. For more information, see Denver Water’s website at: http://www.denverwater.org/Conservation/Xeriscape/	
Replacement Standard	N/A
N/A	

Outbuildings	
Repair Standard	
<p>Unsafe and blighted structures, including outbuildings, may be removed if it is not financially feasible to complete the repairs required to make them structurally sound, leak-free, with any health or safety hazards stabilized. Detached garages should have operable and lockable doors and windows.</p>	
Replacement Standard	N/A
<p>DOH rehabilitation funds may not be used to replace outbuildings.</p>	

Fencing and Gates	
Repair Standard	
<p>Existing fences shall be in good repair. Holes, broken pickets, torn chain-link fabric, missing top-rails, defective posts or supports, broken or missing masonry units, peeling paint, wobbly gate posts, gates which don't open and close properly, etc. shall be repaired.</p>	
Replacement Standard	
<p>DOH rehabilitation funds may not be used to replace fencing.</p>	

Paving And Walks	
Repair Standard	
<p>Sidewalks, driveways, and concrete or asphalt paved pads or parking areas shall be free of trip hazards. Any such surfaces that are excessively cracked, crumbling, irregular, or uneven shall be repaired or replaced. All existing driveways and automobile parking areas which are deteriorated or consist of materials unable to support vehicle traffic shall be removed, improved, or replaced.</p>	
Replacement Standard	
<p>Un-repairable essential walks and driveways shall be replaced with permeable paving, if financially feasible [GREEN STANDARD], or with concrete per local codes (or IEBC). All concrete in public right of way areas shall conform to the local permitting jurisdiction's Building and Planning Department's requirements. Walkways and areas subject to pedestrian traffic shall be finished in such manner as to minimize slip hazards when wet.</p>	

Trees and Shrubbery	
Repair Standard	
<p>Trees that are dead, dying, or hazardous may be removed or trimmed, if that removes the hazard. Trees that could damage the structural integrity of an adjoining building above or below the foundation shall be removed. Removal shall include cutting close to the ground, and should also include grinding of the stump to 12 inches below the finished grade, installation of topsoil and re-seeding.</p>	
Replacement Standard [GREEN STANDARD]	
<p>Replacement trees and shrubs are permitted if economically feasible and shall be selected from the State Extension Service list of local, drought-resistant and non-invasive plant materials. In placement of trees, attention should be paid to shading the building to reduce air conditioning costs. Also, trees should be located a sufficient distance from foundations, sidewalks, walkways, driveways, patios and sidewalks in order to avoid future damage from root growth, branches brushing against the structure, and fire. Setbacks from structures should typically exceed half of the canopy diameter of a full-grown example of the species.</p>	

Lawn [GREEN STANDARD]	
Repair Standard	
<p>Bare section of lawn may be reseeded with drought-resistant grasses or plantings. For more information, see Denver Water’s website at: http://www.denverwater.org/Conservation/Xeriscape/</p>	
Replacement Standard	
<p>Over-seeding is permitted with drought-resistant varieties. If lawn grasses do not exist at property, drought-resistant sod can be used for renovation if existing vegetation is removed and the underlying soil is tilled or core cultivated (aerified).</p>	

3) Building Exterior

NOTE: Any exterior work on a building that is historic shall follow the Colorado State Historic Preservation Office guidelines and any applicable local or federal regulations on historic properties.

Exterior Cladding [MAJOR SYSTEM] [GREEN STANDARD]	
Repair Standard	
Siding and trim shall be intact and weather tight and shall not permit the entry of water, snow, wind, or rodents into the interior. They shall be free of holes and broken or rotted finish materials and shall be capable of being kept in a clean and sanitary condition. All painted exterior components shall have a minimum of one continuous coat of paint, and no exterior painted surface shall have any deteriorated paint. Buildings designated as historic shall have existing siding repaired to blend with existing and shall be spot-primed and top-coated in a lead-safe manner.	
Replacement Standard	
Buildings may have siding replaced with wood, vinyl or cementitious siding to match the existing configuration. New wood components shall be FSC certified: http://www.fsc.org/ . All new surfaces that will receive paint shall be primed prior to painting.	

Exterior Porches	
Repair Standard	
Deteriorated concrete porches shall be repaired when possible. Unsafe wood porch components shall be repaired when possible. Porch repairs shall be structurally sound, with smooth and even decking surfaces. Deteriorated wood structural components shall be replaced with preservative-treated wood.	
Replacement Standard	
Decks and railings on porches shall be replaced in accordance with local codes (or IEBC). Replaced wood structural components shall be preservative-treated. New porches on historic buildings shall be historically sensitive.	

Exterior/Interior Railings	
Repair Standard	
Existing handrails and railings shall be structurally sound and meet local codes (or IEBC). Guard rails are required on any accessible area, including stairs, with a walking surface over 30" above the adjacent ground level. Structurally sound railings may be repaired if it is possible to maintain the existing style. On historic structures, railing repairs shall be historically sensitive.	
Replacement Standard	
Handrails shall be present on one side of all interior and exterior steps or stairways with more than two risers and around steps, porches or platforms over 30" above the adjacent ground level, and shall meet local codes (or IEBC). On historic structures new exterior railings shall be historically sensitive.	

Exterior Decks and Exterior/Interior Steps	
Repair Standard	
Steps, stairways, and porch decks shall be structurally sound, reasonably level, with smooth and even surfaces. Repairs shall match existing materials.	
Replacement Standard	
Decks and steps shall be constructed to meet local codes (or IEBC). Replaced wood structural components shall be preservative-treated. On historic structures new wood decking shall be structurally sound and historically sensitive.	

4) Foundations and Structure

Firewalls [MAJOR SYSTEM]	
Repair Standard	
Firewalls (between separate dwelling units and between dwelling units and attached garages) shall be maintained without cracks and plaster deterioration and covered with 5/8" type X gypsum, glued and screwed to structure.	
Replacement Standard	
When frame walls and floors adjoining other dwellings or attached garages are gutted, new wall finish installations shall conform to local codes (or IEBC) for fire ratings.	

Foundations [MAJOR SYSTEM]	
Repair Standard	
Foundations shall be repaired to be sound, reasonably level, free from movement, and prevent the entrance of water or moisture. Cracks in foundation walls shall be effectively sealed and loose or defective mortar joints shall be replaced. All foundations that show evidence of leakage from the outside require appropriate and effective waterproofing. All earth-to-wood contact shall be eliminated.	
Replacement Standard	
Foundation replacements shall be completed to meet local codes (or IEBC).	

Structural Walls [MAJOR SYSTEM]	
Repair Standard	
Structural framing and masonry shall be free from visible deterioration, rot, or serious termite damage, and be adequately sized for current loads. Prior to rehab, all sagging rafters shall be visually inspected, and significant structural damage and its cause shall be corrected.	
Replacement Standard	
New structural walls shall be constructed to meet local codes or (IEBC). All exterior walls that are part of the building envelope (the air barrier and thermal barrier separating the conditioned space from the non-conditioned space) shall be insulated to meet local codes (or IEBC).	

5) Windows and Doors

Interior Doors	
Repair Standard	
Interior door, frames, jambs and casings shall be in good condition and free of excessive scratches, gouges, chipping, peeling, or other unsightly damage or wear and in good working order. Doors shall be free of holes, delaminating skins, broken stiles or rails. Gaps should be sufficient to prevent rubbing but no larger than ¼". Baths and occupied bedrooms shall have operating doors and lock sets.	
Replacement Standard	
Hollow-core, pressed-wood product consistent with the style of existing doors including latch-sets. Baths and occupied bedrooms shall have lock sets.	

Exterior Doors [MAJOR SYSTEM]	
Repair Standard	
<p>Exterior door, frames, jambs and trim shall be in good condition and free of excessive scratches, gouges, chipping, peeling, or other unsightly damage or wear and in good working order. Doors shall be free of holes, delaminating skins, broken stiles or rails. Exterior doors shall be solid, weather-stripped to be air tight and shall operate smoothly. They shall include a peep sight, an entrance lock set and a deadbolt that is operable from the interior side without the use of a key, tool or special knowledge. Security or screen doors shall be in good working condition, including any latches and locks, and no broken glass and ripped or torn screens should be present.</p>	
Replacement Standard	
<p>Replacement doors at the front of historic buildings shall be historically sensitive. Steel, insulated doors may be installed at entrances not visible from the front street and on the front of the property for buildings that are not historic. Dead bolt locks that are operable from the interior side without the use of a key, tool or special knowledge shall be installed on all exterior doors and keyed to match the entrance lock set. All new doors shall be weather-stripped to be air tight. Security or Screen doors may be replaced if repairs are not feasible.</p>	

Windows [MAJOR SYSTEM] [GREEN STANDARD]	
Repair Standard	
<p>Other than fixed windows, all windows shall be capable of being easily opened and closed, remain in an open position when placed there by window hardware, not sticks or other such items. Windows shall lock when closed and the open section shall be covered with a screen. Glass shall be free of open holes or cracks and secured with an adequate amount of putty. Windows shall be weather-stripped to be air tight when closed.</p>	
Replacement Standard	
<p>Windows that are not repairable shall be replaced. New windows shall meet all requirements of current local building codes or (IEBC) and shall meet the ENERGY STAR standard for this geographic region. For more information: http://www.energystar.gov/index.cfm?c=windows_doors.pr_anat_window Windows on key façades of historically sensitive properties shall be wood of the style original to the building. New windows on other properties may be vinyl and double-glazed.</p>	

Basement Windows and Ventilation [MAJOR SYSTEM]	
Repair Standard	
If feasible, two basement windows on opposite sides of the building should be operable for ventilation, in good working order, and lockable.	
Replacement Standard	
Basement windows may be replaced with glass block, so long as a minimum of two glass block windows on opposite sides of the building have operable and lockable center vents. If the basement is used as a sleeping or living area, please refer to Section 1 for Fire Safety – Egress requirements.	

6) Roofing

Flat and Low-Slope Roofing [MAJOR SYSTEM]	
Repair Standard	
Built-up roofing that is leak-free may be repaired so that the roof is free of peeling, shipping, sloughing, fissures, cracks, lifting seams, excessive bubbles or excessive alligating in coatings or asphalt flood coats. Roof coatings shall be in good condition and consist of compatible materials. Gravel roofs shall have gravel present in sufficient quantity and proper distribution. Flashing and accessories shall be repaired and properly sealed. Asphalt shingles or cold-application rolled roofing shall be replaced if the roof slope is less than 2:12.	
Replacement Standard	
The most cost-effective roof shall be installed to the manufacturer’s specifications and in accordance with local codes (or IEBC).	

Pitched Roofs [MAJOR SYSTEM]	
Repair Standard	
Missing and leaking shingles and flashing shall be repaired on otherwise functional roofs provided there are no excessive lumps, breaks, tears, inconsistent birdsmouths, and the shingle roof has substantial well adhered mineral surface covering the tabs and grooves. Shingle roofs with loose minerals surface, sparsely covered surfaces, excessive curling, cupping, breakage or brittleness should be replaced. Slate, metal and tile roofs shall be repaired when feasible.	

Replacement Standard	
<p>The most cost-effective roof shall be installed except that roofing may be installed to match other structures in the complex, or to preserve other architectural elements. On historic structures new roofing shall be historically sensitive. All roofing shall be installed to the manufacturer's specifications and in accordance with local codes (or IEBC).</p>	

Gutters and Downspouts [MAJOR SYSTEM] [GREEN STANDARD]	
Repair Standard	
<p>Gutters and downspouts shall be in good repair, leak free and collect storm water from all lower roof edges. Concrete splash blocks shall be installed to move water away from the foundation. The system shall move all storm water away from the building and prevent water from entering the structure. In addition to positive drainage away from the building, outlets shall be a minimum of 3 feet away from the foundation.</p>	
Replacement Standard	
<p>Gutters and downspouts shall be installed and collect storm water from all lower roof edges. Concrete splash blocks shall be installed to move water away from the foundation. The system shall move all storm water away from the building and prevent water from entering the structure. In addition to positive drainage away from the building, outlets shall be a minimum of 3 feet away from the foundation.</p>	

7) Insulation and Ventilation

Infiltration [GREEN STANDARD]	
Repair Standard	
<p>Any unit receiving energy-efficiency improvements shall be tested with a Blower Door and existing air sealing shall be repaired to attain a maximum 0.35 Air Changes per Hour at 50 Pascal pressure (0.35 ACH50).</p>	
Replacement Standard	
<p>All units shall be air sealed to meet the minimum Blower Door test requirements of 0.35 Air Changes per Hour at 50 Pascal pressure (0.35 ACH50).</p>	

Insulation [GREEN STANDARD]	
Repair Standard	
<p>If being added, insulation shall be installed per the manufacturer’s instructions and at the recommended R-value for the dimensional lumber used in the wall construction. All exposed heat ducts and hot water or steam heat distribution piping along with general use hot water piping which are located in unheated spaces shall be insulated or otherwise protected from heat loss. All water distribution piping shall be protected from freezing.</p>	
Replacement Standard	
<p>When siding is being replaced and/or interior wall finishes of exterior walls are being replaced in a building, such exterior walls are to be provided with insulation and at the recommended R-value for the dimensional lumber used to construct walls. The ENERGY STAR Thermal Bypass Inspection Checklist should be completed, found at: http://www.energystar.gov/ia/partners/bldrs_lenders_raters/downloads/Thermal_Bypass_Inspection_Checklist.pdf</p>	

Bath Ventilation [MAJOR SYSTEM] [GREEN STANDARD]	
Repair Standard	
<p>All bathroom ventilation shall meet the local building code (or IEBC) for bath ventilation that was in effect at the time of their construction.</p>	
Replacement Standard	
<p>All bathrooms shall be mechanically vented to the ≥ 80 CFM creating ≤ 0.3 Sones of fan noise and shall be on the same switch as the bathroom light. Fans shall be installed according to manufacturer’s specifications and shall meet the local building code (or IEBC).</p>	

Kitchen Ventilation [MAJOR SYSTEM] [GREEN STANDARD]	
Repair Standard	
<p>All kitchen ventilation shall be functional and meet the local building code (or IEBC) for kitchen ventilation that was in effect at the time of their construction.</p>	
Replacement Standard	
<p>All kitchens shall have functional mechanical ventilation operating at a minimum 150 CFM. Any new ventilation system shall meet current local code requirements (or IEBC).</p>	

Roof Ventilation [MAJOR SYSTEM] [GREEN STANDARD]	
Repair Standard	
All structures shall meet the local building code (or IEBC) for roof ventilation that was in effect at the time of their construction.	
Replacement Standard	
All new roofing systems shall meet current local code requirements (or IEBC) for ventilation.	

8 - Interior Standards

Interior Walls and Ceilings	
Repair Standard	
Walls should be smooth wood, plywood, plaster or sheetrock/drywall. All interior walls shall be finished without noticeable irregularities, be free of exposed wiring, have a hard waterproof surface in areas subject to moisture, shall not allow significant entry of air in the unit, and shall be durably painted or otherwise appropriately finished. Holes, cracks and deteriorated and un-keyed plaster shall be repaired to match the surrounding surfaces. All visual painted surfaces shall be stabilized to minimize lead paint hazards using premium vinyl acrylic paint.	
Replacement Standard	
All walls, in areas not subject to moisture, shall be replaced with ½" sheetrock/drywall. All replaced sheetrock/drywall shall be taped, floated, sanded, textured to match other wall areas, primed and painted. Moisture resistant materials shall be used in areas subject to moisture. All Fire-rated assemblies shall be specified on a project-by-project basis as required by local codes (or IEBC).	

Flooring	
Repair Standard	
Floor framing shall be capable of supporting existing dead load and anticipated live loads as appropriate for type of structure and class of occupancy. All subfloors should be solid and continuous, without liberal movement or bounce, and free from rot and deterioration. Bathroom, kitchen and other water-susceptible floor areas shall be covered with water-resistant flooring that is free from tears or tripping hazards. Wood floors shall be in sound	

condition without excessive gouges, breakage, lifting, curling, buckling, or shrinking. Carpet shall be clean and in safe and sanitary condition free or excessive wear, tears, soil, folds, and shall be property attached. Tile floors shall be free of cracked, broken, loose or missing tiles with grout intact.

[GREEN STANDARD] Damaged wood floor shall be repaired when possible. When existing deteriorated carpet is installed over hardwood floors, the hardwood may be refinished whenever practical, taking into account the relative cost of replacing carpet and the needs of the residents.

Replacement Standard

Floor framing shall meet local code requirements (or IEBC). Subfloors shall be a minimum of ¾ inch plywood. Kitchens, baths, and other water-susceptible area shall receive resilient sheet goods.

[GREEN STANDARD] Whenever practical, rooms other than kitchens and baths with existing wood flooring shall be maintained as wood floors and refinished when appropriate. Rooms other than kitchens or baths without usable wood floors may be finished with carpet and associated products that are Carpet and Rug Institute’s Green Label certified. For more information: <http://www.carpet-rug.org/residential-customers/selecting-the-right-carpet-or-rug/green-label.cfm>

All new flooring shall be installed in accordance with manufacturer’s recommendations.

New basement slabs shall be installed to local codes (or IEBC).

Closets

Repair Standard

Existing closets shall be maintained in good repair and have a shelf and clothes rod.

Replacement Standard

New closets may be created if there is a significant lack of storage space and the budget permits. New closets shall have a minimum depth of 2 feet and include a shelf and clothes rod.

Cabinets and Countertop	
Repair Standard	
Kitchens shall have countertop and storage space adequate for the preparation and storage of food. Countertops shall free of wear, water damage, and uplifting of surface material. Existing cabinets with hardwood doors and face frames may be repaired if in good condition. All cabinets shall be sound and cleanable with no missing doors, drawers or hardware. All doors and drawers shall operate properly.	
Replacement Standard	
Kitchens shall have countertop and storage space adequate for the preparation and storage of food. Countertops shall be of water-proof material and backsplashes shall be provided. Replacement cabinets shall be factory-finished builders-grade or better with hardwood doors and face frames.	

Appliances	
Repair Standard	
All appliances in units shall be in proper working order and in clean and sanitary condition.	

Replacement Standard	
All new appliances shall be “Energy Star” rated.	

9) Electric

Note: If there is no local building code, then all electrical work shall comply with the State Code (the National Electrical Code, 2011 Edition, as may be amended by the Colorado Electrical Board).

Lighting	
Repair Standard	
All halls, stairs and rooms necessary to cross to other rooms and stairways shall be well lit. All lights and switches in hallways, stairs and other passages shall be operable and safe.	
[GREEN STANDARD] Existing fixtures with incandescent lamp fittings shall have CFL replacement lamps installed.	

Replacement Standard	
All halls, stairs and rooms necessary to cross to other rooms and stairways shall be well lit. Attics, basements and crawl spaces shall have utility fixtures. All new light fixtures shall be ENERGY STAR labeled.	

Interior Electric Distribution [MAJOR SYSTEM]	
Repair Standard	
Exposed knob and tube shall be replaced. Every room shall have a minimum of two duplex receptacles, placed on separate walls and one light fixture or receptacle switched at each room entrance. All electrical outlets used in bathrooms and toilet rooms, kitchens, all outlets within six feet (6') of a water source (excluding washing machines and sump pumps), outlets located on open porches or breezeways, exterior outlets, outlets located in garages and in non-habitable basements, except those outlets that are dedicated appliance outlets, shall be Ground-Fault Circuit Interrupter (GFCI) protected. Where the source wiring circuit is accessible (e.g. first floor above basements, in gutted rooms, etc.), receptacles shall be grounded. Permanently installed or proposed stoves, refrigerators, freezers, dishwashers and disposals, microwaves, washers and dryers shall have separate circuits sized to meet local codes (or State Electrical code). All switch, receptacle, and junction boxes shall have appropriate cover plates. Wiring shall be free from hazard, and all circuits shall be properly protected at the panel. Exposed conduit is allowed.	
Replacement Standard	
If wall finishes are removed, those areas shall be wired to the latest version of local codes (or State Electrical Code).	

Service and Panel [MAJOR SYSTEM]	
Repair Standard	
Each units electrical service shall be circuit breaker type. Service panels shall have a main disconnect, at least 10 circuit-breaker-protected circuits, a 100-amp minimum capacity and be adequate to safely supply existing and proposed devices. If a working central air conditioning system is present, the minimum service shall be 150 amp.	
Replacement Standard	
Electrical service with a main disconnect panel shall be installed according to local code (or State Electrical Code).	

10) Plumbing

Note: If there is no local building code, then all plumbing work shall comply with the Colorado Plumbing Code.

Drain, Waste, Vent Lines [MAJOR SYSTEM]	
Repair Standard	
<p>The plumbing system shall be vented in a manner that allows the wastewater system to function properly. The waste system shall operate free from fouling, clogging and leaking and shall be capable of safely disposing of wastewater for all plumbing fixtures. All fixtures that discharge wastewater shall contain or be discharged through a trap that prevents the entry of sewer gas into the dwelling. Waste and vent lines shall function without losing the trap seal.</p>	
Replacement Standard	
<p>If walls are removed exposing vent and waste lines, those lines shall be reworked or replaced to the current mechanical code.</p>	

Plumbing Fixtures	
Repair Standard	
<p>All plumbing fixtures shall be free of cracks and defects, and be capable of being used for the purpose in which they were intended. All fixtures and faucets shall have working, drip-free components.</p>	
Replacement Standard	
<p>Replace fixtures with single lever, metal faucets and shower diverters with 15-year, drip-free warranties. Sinks should be replaced with stainless steel sinks, and new tub surrounds should be of fiberglass.</p> <p>[GREEN STANDARD] Toilets with greater than a 1.6 GPF rating shall be replaced with a 1.3 GPF model. Faucets and shower diverters should have a maximum 2.0 GPM flow.</p>	

Plumbing Minimum Equipment [MAJOR SYSTEM]	
Repair Standard	
All existing equipment shall be operational and leak free.	
Minimum Standard	
All existing equipment shall be operational and leak free. Every dwelling unit shall have a minimum of one single bowl sink with hot and cold running water in the kitchen and at least one bathroom containing a vanity with a sink (or pedestal sink), and a shower/tub unit, both with hot and cold running water, and a toilet. An operable water shut off valve, that completely stops the flow of water, shall be present at each water supply line to sinks/lavatories, toilets, washing machines and water heaters. Each unit shall have an adequate continuous supply of hot water either through a minimum 40 gallon water heater or on demand water heater in the unit or through a common boiler or hot water supply for the building. Each building shall have installed at least one exterior freeze protected faucet.	

Water Heaters [MAJOR SYSTEM]	
Repair Standard	
Each housing unit shall be supplied with hot water either from a common source such as building-wide boiler system or from per-unit water heating equipment. Hot water supply lines shall be free of leaks and all water heating equipment shall be safe, of adequate capacity, free of corrosion and water damage, faulty operation, fire, carbon monoxide leakage and other hazards.	
Replacement Standard	
Hot water systems that are replaced shall be of adequate capacity, be installed per manufacturer's specifications and meet local codes (or IEBC).	
[GREEN STANDARD] High efficiency power-vented or sealed combustion tankless models are allowed.	

Water Supply [MAJOR SYSTEM]	
Repair Standard	
<p>The main shut off valve shall be operable and completely stop the flow of water to the house. If there is no existing shut-off valve, then one shall be installed. All fixtures shall be leak-free and deliver sufficient cold water and, where applicable, hot water. All lead supply pipes present shall be completely removed and replaced.</p>	
Replacement Standard	
<p>The main shut off valve shall be operable and completely stop the flow of water to the house, and should be replaced if it does not. Lead and galvanized pipe that is part of the water service or the distribution system shall be replaced with copper, PEX or other plastic approved for distribution of domestic water. All fixtures shall have brass shut off valves.</p>	

11) HVAC

Air Conditioning [MAJOR SYSTEM] [GREEN STANDARD]	
Repair Standard	
<p>Existing air conditioners and evaporative coolers shall be inspected, serviced and refurbished to operate safely. Non-functioning, non-repairable air conditioners and evaporative coolers shall be removed and drained of all CFCs.</p>	
Replacement Standard	
<p>New air conditioning or evaporative cooling units shall be of adequate capacity, and reasonably durable and economical to operate. Any air conditioning or evaporative cooling systems shall be installed in accordance with manufacturer's installation specifications.</p>	

Chimney [MAJOR SYSTEM]	
Repair Standard	
<p>Unused chimneys shall be removed to below the roof line wherever roofing is replaced. Chimneys shall be in good repair and high enough to induce a draft that shall keep smoke from being allowed into the dwelling. Existing unlined masonry chimneys used for combustion ventilation shall be lined or corrosion resistant pipe shall be added to the interior of the chimney.</p>	

Replacement Standard	
The creation of new flues is not recommended - the use of high efficiency closed combustion appliances is recommended to avoid the need for new flues. Replacement flues, when required, shall be installed according to the fuel burning unit manufacturer's installation specifications.	

Distribution System [MAJOR SYSTEM]	
Repair Standard	
Duct work and radiator piping shall be well supported, insulated in unconditioned space and adequate to maintain a comfortable temperature in all habitable and essential rooms.	
[GREEN STANDARD] All duct work in unconditioned space should be insulated to R-7, sealed at all seams with mastic (not tape) and pressure tested to eliminate leakage.	
Replacement Standard	
All duct work in unconditioned space shall be insulated to R-7, sealed at all seams with mastic (not tape), pressure tested to eliminate leakage and run in concealed space.	

Heating [MAJOR SYSTEM]	
Repair Standard	
All heating equipment shall be safe, of adequate capacity, free of corrosion and water damage, faulty operation, fire, carbon dioxide leakage and other hazards. Filters shall be secure, clean and large enough to pass sufficient recirculated air to make the unit operate properly. Equipment housings and access panels shall be intact and properly secured/installed with no exposed electrical connections, belts, pulleys, or blowers.	
Replacement Standard	
Gas-fired heating plants shall be rated at $\geq 92\%$ AFUE or better, to the extent possible. Heat pumps shall be rated at ≥ 15 SEER. No Oil fired heating plants shall be installed and the oil heating system, including tanks and fuel lines, shall be completely removed before being replaced with new gas or electric systems. Setback thermostats may be installed. When electric resistance heating systems are replaced, soffits for ductwork and/or new distribution pipes for hot water heating systems shall be provided. Up to 4 lineal feet of resistance electric heating strips per 1000 square feet of floor area may be retained or installed in areas that are not cost effective to heat via ductwork or hot water distribution systems. All heating equipment shall be installed as per manufacturer' installation specifications and local codes (or IEBC).	

Multifamily Rehabilitation Standards Appendix A: Uniform Physical Condition Standards for Multifamily Housing Rehabilitation		
NOTE: Observable Deficiencies in <i>*Bold Italic</i> are considered life-threatening and must be addressed immediately, if the housing is occupied.		
Inspectable Item	Observable Deficiency	Type and Degree of Deficiency that must be addressed
Requirements for Site		
Fencing and Gates	Damaged/Falling/Leaning	Fence or gate is so damaged that it does not function as it should
	Holes	Hole in fence or gate is larger than 6 inches by 6 inches
	Missing Sections	An exterior fence, security fence or gate is missing a section which could threaten safety or security
Grounds	Erosion/Rutting Areas	Runoff has extensively displaced soils which has caused visible damage or potential failure to adjoining structures or systems and potentially threatens the safety of pedestrians
	Overgrown/Penetrating Vegetation	Plants have visibly damaged a component, area or system of the property or has made them unusable or unpassable
	Ponding/Site Drainage	There is an accumulation of more than 5 inches deep or a large section of the grounds-more than 20%-is unusable for it's intended purpose
Health & Safety	Air Quality - Sewer Odor Detected	Detectable sewer odors that could pose a health risk if inhaled for prolonged periods
	<i>*Air Quality - Propane/Natural Gas/Methane Gas Detected</i>	Detectable strong propane, natural gas or methane gas odors that could pose a risk of explosion/ fire and/or pose a health risk if inhaled
	<i>*Electrical Hazards - Exposed Wires/Open Panels</i>	Exposed bare wires or openings in electrical panels (capped wires do not pose a risk)
	<i>*Electrical Hazards - Water Leaks on/near Electrical Equipment</i>	Water leaking, puddling or ponding on or immediately near any electrical apparatus that could pose a risk of fire, electrocution or explosion
	<i>*Flammable Materials - Improperly Stored</i>	Flammable materials are improperly stored, causing the potential risk of fire or explosion
	Garbage and Debris - Outdoors	Too much garbage has gathered-more than the planned storage capacity, or garbage has gathered in an area not sanctioned for staging or storing garbage or debris
	Hazards - Other	General defects or hazards that pose risk of bodily injury
	Hazards - Sharp Edges	Physical defects that could cause cutting or breaking of human skin or other bodily harm
	Hazards - Tripping	Physical defects in walkways or other travelled area that poses a tripping risk
	Infestation - Insects	Evidence of infestation of insects-including roaches and ants-throughout a unit or room, especially in food preparation and storage areas
	Infestation - Rats/Mice/Vermin	Evidence of rats or mice--sightings, rat or mouse holes, or droppings
Mailboxes/Project Signs	Mailbox Missing/Damaged	The U.S. Postal Service resident/unit mailbox cannot be locked or is missing
	Signs Damaged	The sign is damaged, vandalized, or deteriorated, and cannot be read from a reasonable distance
Parking Lots/Driveways/Roads	Cracks	Cracks greater than ¼ inch, hinging/tilting, or missing section(s) that affect traffic ability over more than 5% of the property's parking lots/driveways/roads or if a height differential could cause a tripping or falling hazard
	Ponding	3 inches or more of water has accumulated making 5% or more of a parking lot/driveway unusable or unsafe
	Potholes/Loose Material	Potholes or loose material that have made a parking lot/driveway unusable/unpassable for vehicles and/or pedestrians or could cause tripping or falling
	Settlement/Heaving	Settlement/heaving has made a parking lot/driveway unusable/unpassable or creates unsafe conditions for pedestrians and vehicles
Play Areas and Equipment	Damaged/Broken Equipment	More than 20% of the equipment does not operate as it should or equipment that poses a threat to safety and could cause injury
	Deteriorated Play Area Surface	More than 20% of the play surface area shows deterioration or the play surface area could cause tripping or falling and thus poses a safety risk
Refuse Disposal	Broken/Damaged Enclosure-Inadequate Outside Storage Space	A single wall or gate of the enclosure has collapsed or is leaning and in danger of falling or trash cannot be stored in the designated area because it is too small to store refuse until disposal
Retaining Walls	Damaged/Falling/Leaning	A retaining wall is damaged and does not function as it should or is a safety risk
		The system is partially or completely blocked by a large quantity of debris , causing backup into adjacent areas or runoffs into areas where runoff is not intended
Storm Drainage	Damaged/Obstructed	
Walkways/Steps	Broken/Missing Hand Railing	The hand rail is missing, damaged, loose or otherwise unusable
	Cracks/Settlement/Heaving	Cracks greater than 3/4", hinging/tilting or missing sections that affect traffic ability over more than 5% of the property's walkways/steps or any defect that creates a tripping or falling hazard
	Spalling/Exposed rebar	More than 5% of walkways have large areas of spalling--larger than 4 inches by 4 inches--and this affects traffic ability

Multifamily Rehabilitation Standards Appendix A: Uniform Physical Condition Standards for Multifamily Housing Rehabilitation		
NOTE: Observable Deficiencies in <i>*Bold Italic</i> are considered life-threatening and must be addressed immediately, if the housing is occupied.		
Inspectable Item	Observable Deficiency	Type and Degree of Deficiency that must be addressed
Requirements for Building Exterior		
Doors	Damaged Frames/Threshold/Lintels/Trim	Any door that is not functioning or cannot be locked because of damage to the frame, threshold, lintel or trim
	Damaged Hardware/Locks	Any door that does not function as it should or cannot be locked because of damage to the door's hardware
	Damaged Surface (Holes/Paint/Rusting/Glass)	Any door that has a hole or holes larger than 1 inch in diameter, significant peeling/cracking/no paint or rust that affects the integrity of the door surface, or broken/missing glass
	Damaged/Missing Screen/Storm/Security Door	Any screen door or storm door that is damaged or is missing screens or glass-- shown by an empty frame or frames or any security door that is not functioning or is missing
	Deteriorated/Missing Caulking/Seals	The seals/caulking is missing on any entry door, or they are so damaged that they do not function as they should
	Missing Door	Any exterior door that is missing
Fire Escapes	*Blocked Egress/Ladders	Stored items or other barriers restrict or block people from exiting
	Visibly Missing Components	Any of the functional components that affect the function of the fire escape-- one section of a ladder or railing, for example--are missing
Foundations	Cracks/Gaps	Large cracks or gaps in foundation more than 3/8 inches wide by 3/8 inches deep by 6 inches long that present a possible sign of a serious structural problem, or opportunity for water penetration or sections of wall or floor that are broken apart
	Spalling/Exposed Rebar	Significant spalled areas affecting more than 10% of any foundation wall or any exposed reinforcing material--rebar or other
Health and Safety	*Electrical Hazards - Exposed Wires/Open Panels	Exposed bare wires or openings in electrical panels (capped wires do not pose a risk)
	*Electrical Hazards - Water Leaks on/near Electrical Equipment	Water leaking, puddling or ponding on or immediately near any electrical apparatus that could pose a risk of fire, electrocution or explosion
	*Emergency Fire Exits - Emergency/Fire Exits Blocked/Unusable	The exit cannot be used or exit is limited because a door or window is nailed shut, a lock is broken, panic hardware is chained, debris, storage, or other conditions block exit
	*Emergency Fire Exits - Missing Exit Signs	Exit signs that clearly identify all emergency exits are missing or there is no illumination in the area of the sign
	*Flammable/Combustible Materials - Improperly Stored	Flammable materials are improperly stored, causing the potential risk of fire or explosion
	Garbage and Debris - Outdoors	Too much garbage has gathered--more than the planned storage capacity or garbage has gathered in an area not sanctioned for staging or storing garbage or debris
	Hazards - Other	General defects or hazards that pose risk of bodily injury
Lighting	Hazards - Sharp Edges	Physical defects that could cause cutting or breaking of human skin or other bodily harm
	Hazards - Tripping	Physical defects in walkways or other travelled area that poses a tripping risk
	Infestation - Insects	Evidence of infestation of insects--including roaches and ants--throughout a unit or room, especially in food preparation and storage areas
	Infestation - Rats/Mice/Vermin	Evidence of rats or mice--sightings, rat or mouse holes, or droppings
Roofs	Broken Fixtures/Bulbs	Lighting fixtures and bulbs are broken or missing
Walls	Damaged Soffits/Fascia	Soffits or fascia that should be there are missing or so damaged that water penetration is visibly possible
	Damaged Vents	Vents are missing or so visibly damaged that further roof damage is possible
	Damaged/Clogged Drains	The drain is so damaged or clogged with debris that the drain no longer functions--as shown by ponding
	Damaged/Torn Membrane/Missing Ballast	Ballast has shifted and no longer functions as it should or there is damage to the roof membrane that may result in water penetration
	Missing/Damaged Components from Downspout/Gutter	Drainage system components are missing or damaged causing visible damage to the roof, structure, exterior wall surface, or interior
	Missing/Damaged Shingles	Shingles are missing or damaged, including cracking, warping, cupping, and other deterioration
	Ponding	Evidence of standing water on roof, causing potential or visible damage to roof surface or underlying materials
	Cracks/Gaps	Large cracks or gaps that are more than 3/8 inches wide or deep and 6 inches long that presents a possible sign of serious structural problem or opportunity for water penetration
Walls	Damaged Chimneys	Part or all of the chimney has visibly separated from the adjacent wall or there are cracked or missing pieces large enough to present a sign of chimney failure or there is a risk of falling pieces that could create a safety hazard
	Missing/Damaged Caulking/Mortar	Caulking or glazing compound that resists weather is missing or deteriorated
	Missing Pieces/Holes/Spalling	Exterior wall deterioration or holes of any size that present a risk of water penetration or risk of structural damage
	Stained/Peeling/Needs Paint	Paint is cracking, flaking, or otherwise deteriorated. Water damage or related problems have stained the paint

Multifamily Rehabilitation Standards Appendix A: Uniform Physical Condition Standards for Multifamily Housing Rehabilitation		
NOTE: Observable Deficiencies in <i>*Bold Italic</i> are considered life-threatening and must be addressed immediately, if the housing is occupied.		
Inspectable Item	Observable Deficiency	Type and Degree of Deficiency that must be addressed
Windows	Broken/Missing/Cracked Panes	Missing or cracked panes of glass
	Damaged Sills/Frames/Lintels/Trim	Window sills, frames, sash lintels, or trim are damaged by decay, rust, rot, corrosion, or other deterioration
	Damaged/Missing Screens	Missing screens or screens are punctured, torn or otherwise damaged
	Missing/Deteriorated Caulking/Seals/Glazing Compound	Caulking or seals that resists weather is missing or deteriorated
	Peeling/Needs Paint	Paint covering the window assembly or trim is cracking, flaking, or otherwise failing
	<i>*Security Bars Prevent Egress</i>	The ability to exit through egress window is limited by security bars that do not function properly and, therefore, pose safety risks
Requirements for Building Systems		
Inspectable Item	Observable Deficiency	Type and Degree of Deficiency that must be addressed
Domestic Water	Leaking Central Water Supply	Leaking water from water supply line is observed
	Missing Pressure Relief Valve	No pressure relief valve or pressure relief valve does not drain down to the floor
	Rust/Corrosion on Heater Chimney	Water heater chimney shows evidence of flaking, discoloration, pitting, or crevices that may create holes that could allow toxic gases to leak from the chimney
	Water Supply Inoperable	No running water in any area of the building where there should be
Electrical System	Blocked Access/Improper Storage	One or more fixed items or items of sufficient size and weight impede access to the building system's electrical panel during an emergency
	Burnt Breakers	Carbon residue, melted breakers or arcing scars are evident
	Evidence of Leaks/Corrosion	Corrosion that affects the condition of the components that carry current or any stains or rust on the interior of electrical enclosures, or any evidence of water leaks in the enclosure or hardware
	Frayed Wiring	Nicks, abrasion, or fraying of the insulation that exposes any conducting wire
	Missing Breakers/Fuses	Open and/or exposed breaker port
	<i>*Missing Outlet Covers</i>	A cover is missing, which results in exposed visible electrical connections
Elevators	Not Operable	Elevator does not function at all or the elevator doors open when the cab is not there
Emergency Power	Auxiliary Lighting Inoperable (if applicable)	Auxiliary lighting does not function
Fire Protection	Missing Sprinkler Head	Any sprinkler head is missing, visibly disabled, painted over, blocked, or capped
	<i>*Missing/Damaged/Expired Extinguishers</i>	Missing, damaged or expired fire extinguisher in any area of the building where a fire extinguisher is required
Health & Safety	Air Quality - Mold and/or Mildew Observed	Evidence of mold or mildew is observed that is substantial enough to pose a health risk
	<i>*Air Quality - Propane/Natural Gas/Methane Gas Detected</i>	Detectable strong propane, natural gas or methane gas odors that could pose a risk of explosion/ fire and/or pose a health risk if inhaled
	Air Quality - Sewer Odor Detected	Detectable sewer odors that could pose a health risk if inhaled for prolonged periods
	<i>Electrical Hazards - Exposed Wires/Open Panels</i>	Exposed bare wires or openings in electrical panels (capped wires do not pose a risk)
	<i>*Electrical Hazards - Water Leaks on/near Electrical Equipment</i>	Water leaking, puddling or ponding on or immediately near any electrical apparatus that could pose a risk of fire, electrocution or explosion
	Elevator - Tripping	Elevator is misaligned with the floor by more than 3/4 of an inch. The elevator does not level as it should, which causes a tripping hazard
	<i>*Emergency Fire Exits - Emergency/Fire Exits Blocked/Unusable</i>	The exit cannot be used or exit is limited because a door or window is nailed shut, a lock is broken, panic hardware is chained, debris, storage, or other conditions block exit
	<i>*Emergency Fire Exits - Missing Exit Signs</i>	Exit signs that clearly identify all emergency exits are missing or there is no illumination in the area of the sign
	<i>*Flammable Materials - Improperly Stored</i>	Flammable materials are improperly stored, causing the potential risk of fire or explosion
	Garbage and Debris - Indoors	Too much garbage has gathered-more than the planned storage capacity or garbage has gathered in an area not sanctioned for staging or storing garbage or debris
	Hazards - Other	General defects or hazards that pose risk of bodily injury
	Hazards - Sharp Edges	Physical defects that could cause cutting or breaking of human skin or other bodily harm
	Hazards - Tripping Hazards	Physical defects in walkways or other travelled area that poses a tripping risk
	Infestation - Insects	Evidence of infestation of insects-including roaches and ants-throughout a unit or room, especially in food preparation and storage areas
	Infestation - Rats/Mice/Vermin	Evidence of rats or mice--sightings, rat or mouse holes, or droppings
HVAC	Boiler/Pump Leaks	Evidence of water or steam leaking in piping or pump packing
	Fuel Supply Leaks	Evidence of any amount of fuel leaking from the supply tank or piping
	General Rust/Corrosion	Significant formations of metal oxides, significant flaking, discoloration, or the development of a noticeable pit or crevice

Multifamily Rehabilitation Standards Appendix A: Uniform Physical Condition Standards for Multifamily Housing Rehabilitation		
NOTE: Observable Deficiencies in <i>*Bold Italic</i> are considered life-threatening and must be addressed immediately, if the housing is occupied.		
Inspectable Item	Observable Deficiency	Type and Degree of Deficiency that must be addressed
	<i>*Misaligned Chimney/Ventilation System</i>	A misalignment of an exhaust system on a combustion fuel-fired unit (oil, natural gas, propane, wood pellets etc.) that causes improper or dangerous venting of gases
Roof Exhaust System	Roof Exhaust Fan(s) Inoperable	Roof exhaust fan unit does not function
Sanitary System	Broken/Leaking/Clogged Pipes or Drains	Evidence of active leaks in or around the system components or evidence of standing water, puddles or ponding--a sign of leaks or clogged drains
	Missing Drain/Cleanout/Manhole Covers	A protective cover is missing
Requirements for Common Areas		
Inspectable Item	Observable Deficiency	Type and Degree of Deficiency that must be addressed
Basement/Garage/Carport	Baluster/Side Railings - Damaged	Damaged or missing balusters or side rails that limit the safe use of an area
Closet/Utility/Mechanical	Cabinets - Missing/Damaged	Cabinets are missing or the laminate is separating. This includes cases, boxes, or pieces of furniture with drawers, shelves, or doors--primarily used for storage--mounted on walls or floors
Community Room	Call for Aid - Inoperable	The system does not function as it should
Halls/Corridors/Stairs	Ceiling - Holes/Missing Tiles/Panels/Cracks	Ceiling surface has punctures that may or may not penetrate completely or panels or tiles are missing
Kitchen	Ceiling - Peeling/Needs Paint	Paint is peeling, cracking, flaking, or otherwise deteriorated on ceilings in common areas
Laundry Room	Ceiling - Water Stains/Water Damage/Mold/Mildew	Evidence of water infiltration, mold, or mildew that may have been caused by saturation or surface failure
Lobby	Countertops - Missing/Damaged	Flat work surface in a kitchen often integral to lower cabinet space is missing or deteriorated or damaged below the laminate
Office	Dishwasher/Garbage Disposal - Inoperable	Dishwasher or garbage disposal does not operate as it should
Other Community Spaces	Doors - Damaged Frames/Threshold/Lintels/Trim	Any door that is not functioning or cannot be locked because of damage to the frame, threshold, lintel or trim
Patio/Porch/Balcony	Doors - Damaged Hardware/Locks	Any door that does not function as it should or cannot be locked because of damage to the door's hardware
Restrooms	Doors - Damaged Surface (Holes/Paint/Rust/Glass)	Any door that has a hole or holes greater than 1 inch in diameter, significant peeling/cracking/no paint or rust that affects the integrity of the door surface, or broken/missing glass
Storage	Doors - Damaged/Missing Screen/Storm/Security Door	Any screen door or storm door that is damaged or is missing screens or glass--shown by an empty frame or frames or any security door that is not functioning or is missing
	Doors - Deteriorated/Missing Seals (Entry Only)	The seals/caulking is missing on any entry door, or they are so damaged that they do not function as they should
	Doors - Missing Door	Any door that is missing that is required for the functional use of the space
	Dryer Vent -Missing/Damaged/Inoperable	Dryer vent is missing or it is not functioning because it is blocked. Dryer exhaust is not effectively vented to the outside
	Electrical - Blocked Access to Electrical Panel	One or more fixed items or items of sufficient size and weight impede access to the building system's electrical panel during an emergency
	Electrical - Burnt Breakers	Carbon residue, melted breakers or arcing scars are evident
	Electrical - Evidence of Leaks/Corrosion	Corrosion that affects the condition of the components that carry current or any stains or rust on the interior of electrical enclosures or any evidence of water leaks in the enclosure or hardware
	Electrical - Frayed Wiring	Nicks, abrasion, or fraying of the insulation that exposes any conducting wire
	Electrical - Missing Breakers	Open and/or exposed breaker port
	<i>*Electrical - Missing Covers</i>	A cover is missing, which results in exposed visible electrical connections
	Floors - Bulging/Buckling	Flooring that is bulging, buckling or sagging or a problem with alignment between flooring types
	Floors - Floor Covering Damaged	Floor covering has stains, surface burns, cuts, holes, tears, loose areas or exposed seams
	Floors - Missing Floor/Tiles	Flooring or tile flooring that is missing
	Floors - Peeling/Needs Paint	Painted flooring that has peeling or missing paint
	Floors - Rot/Deteriorated Subfloor	Rotted or deteriorated subflooring
	Floors - Water Stains/Water Damage/Mold/Mildew	Evidence of water infiltration, mold, or mildew that may have been caused by saturation or surface failure
	GFI - Inoperable	The GFI does not function
	Graffiti	Graffiti on any exposed surface greater than 6 inches by 6 inches
	HVAC - Convection/Radiant Heat System Covers Missing/Damaged	Cover is missing or substantially damaged, allowing contact with heating/surface elements or associated fans
	HVAC - General Rust/Corrosion	Significant formations of metal oxides, flaking, or discoloration--or a pit or crevice
	HVAC - Inoperable	HVAC does not function. It does not provide the heating and cooling it should. The system does not respond when the controls are engaged
	<i>*HVAC - Misaligned Chimney/Ventilation System</i>	Any misalignment that may cause improper or dangerous venting of gases
	HVAC - Noisy/Vibrating/Leaking	HVAC system shows signs of abnormal vibrations, other noise, or leaks when engaged
	Lavatory Sink - Damaged/Missing	Sink, faucet, or accessories are missing, damaged, or not functioning

Multifamily Rehabilitation Standards Appendix A: Uniform Physical Condition Standards for Multifamily Housing Rehabilitation		
NOTE: Observable Deficiencies in <i>*Bold Italic</i> are considered life-threatening and must be addressed immediately, if the housing is occupied.		
Inspectable Item	Observable Deficiency	Type and Degree of Deficiency that must be addressed
	Lighting - Missing/Damaged/Inoperable Fixture	Permanent light fixtures are missing or not functioning, and no other switched light source is functioning in the room
	Mailbox - Missing/Damaged	The U.S Postal Service mailbox cannot be locked or is missing
	<i>*Outlets/Switches/Cover Plates - Missing/Broken</i>	Outlet or switch is missing or a cover plate is missing or broken, resulting in exposed wiring
	Pedestrian/Wheelchair Ramp	Walkway or ramp is damaged and cannot be used by people on foot, in wheelchair, or using walkers
	Plumbing - Clogged Drains	Drain is substantially or completely clogged or has suffered extensive deterioration
	Plumbing - Leaking Faucet/Pipes	A steady leak that is adversely affecting the surrounding area
	Range Hood /Exhaust Fans - Excessive Grease/Inoperable	Apparatus that draws out cooking exhaust does not function as it should and/or accumulation of dirt threatens the free passage of air
	Range/Stove - Missing/Damaged/Inoperable	One or more burners are not functioning or doors or drawers are impeded or on gas ranges pilot is out and/or flames are not distributed equally or oven not functioning
	Refrigerator - Damaged/Inoperable	Refrigerator is missing or does not cool adequately for the safe storage of food
	Restroom Cabinet - Damaged/Missing	Damaged or missing shelves, vanity top, drawers, or doors that are not functioning as they should for storage or their intended purpose
	Shower/Tub - Damaged/Missing	Shower, tub, or components are damaged or missing
	Sink - Missing/Damaged	Sink, faucet, or accessories are missing, damaged, or not functioning
	<i>*Smoke Detector - Missing/Inoperable</i>	Smoke detector is missing or does not function as it should
	Stairs - Broken/Damaged/Missing Steps	A step is missing or broken
	Stairs - Broken/Missing Hand Railing	Hand rail is missing, damaged, loose or otherwise unusable
	Ventilation/Exhaust System - Inoperable	Exhaust fan is not functioning or window designed for ventilation does not open
	Walls - Bulging/Buckling	Bulging, buckling or sagging walls or a lack of horizontal alignment
	Walls - Damaged	Punctures in the wall surface that may or may not penetrate completely
	Walls - Damaged/Deteriorated Trim	Cove molding, chair rail, base molding, or other decorative trim is damaged or has decayed
	Walls - Peeling/Needs Paint	Paint is peeling, cracking, flaking, or otherwise deteriorated
	Walls - Water Stains/Water Damage/Mold/Mildew	Evidence of water infiltration, mold, or mildew--or damage caused by saturation or surface failure
	Water Closet/Toilet - Damaged/Clogged/Missing	Fixture elements--seat, flush handle, cover etc.--are missing or damaged or the toilet seat is cracked or has a broken hinge or toilet cannot be flushed
	Windows - Cracked/Broken/Missing Panes	Missing or cracked panes of glass
	Windows - Damaged Window Sill	Sill is damaged enough to expose the inside of the surrounding walls and compromise its weather tightness
	Windows - Inoperable/Not Lockable	Window that is not functioning or cannot be secured because lock is broken
	Windows - Missing/Deteriorated Caulking/Seals/Glazing Compound	Caulking or seals that resists weather is missing or deteriorated
	Windows - Peeling/Needs Paint	Paint covering the window assembly or trim is cracking, flaking, or otherwise failing
	<i>*Windows - Security Bars Prevent Egress</i>	The ability to exit through the window is limited by security bars that do not function properly and, therefore, pose safety risks
Health & Safety	Air Quality - Mold and/or Mildew Observed	Evidence of mold or mildew is observed that is substantial enough to pose a health risk
	<i>*Air Quality - Propane/Natural Gas/Methane Gas Detected</i>	Detectable strong propane, natural gas or methane gas odors that could pose a risk of explosion/ fire and/or pose a health risk if inhaled
	Air Quality - Sewer Odor Detected	Detectable sewer odors that could pose a health risk if inhaled for prolonged periods
	<i>*Electrical Hazards - Exposed Wires/Open Panels</i>	Exposed bare wires or openings in electrical panels (capped wires do not pose a risk)
	<i>*Electrical Hazards - Water Leaks on/near Electrical Equipment</i>	Water leaking, puddling or ponding on or immediately near any electrical apparatus that could pose a risk of fire, electrocution or explosion
	<i>*Emergency Fire Exits - Emergency/Fire Exits Blocked/Unusable</i>	The exit cannot be used or exit is limited because a door or window is nailed shut, a lock is broken, panic hardware is chained, debris, storage, or other conditions block exit
	<i>*Emergency Fire Exits - Missing Exit Signs</i>	Exit signs that clearly identify all emergency exits are missing or there is no illumination in the area of the sign
	<i>*Flammable/Combustible Materials - Improperly Stored</i>	Flammable or combustible materials are improperly stored, causing the potential risk of fire or explosion
	Garbage and Debris - Indoors	Too much garbage has gathered-more than the planned storage capacity or garbage has gathered in an area not sanctioned for staging or storing garbage or debris
	Garbage and Debris - Outdoors	Too much garbage has gathered-more than the planned storage capacity or garbage has gathered in an area not sanctioned for staging or storing garbage or debris
	Hazards - Other	General defects or hazards that pose risk of bodily injury
	Hazards - Sharp Edges	Physical defects that could cause cutting or breaking of human skin or other bodily harm

Multifamily Rehabilitation Standards Appendix A: Uniform Physical Condition Standards for Multifamily Housing Rehabilitation		
NOTE: Observable Deficiencies in <i>*Bold Italic</i> are considered life-threatening and must be addressed immediately, if the housing is occupied.		
Inspectable Item	Observable Deficiency	Type and Degree of Deficiency that must be addressed
	Hazards - Tripping	Physical defects in walkways or other travelled area that poses a tripping risk
	Infestation - Insects	Evidence of infestation of insects-including roaches and ants-throughout a unit or room, especially in food preparation and storage areas
	Infestation - Rats/Mice/Vermin	Evidence of rats or mice--sightings, rat or mouse holes, or droppings
Pools and Related Structures	Fencing - Damaged/Not Intact	Damage that could compromise the integrity of the fence
Trash Collection Areas	Chutes - Damaged/Missing Components	Garbage has backed up into chutes, because the collection structure is missing or broken or compactors or components--chute, chute door, and other components--have failed
Requirements for Unit		
Inspectable Item	Observable Deficiency	Type and Degree of Deficiency that must be addressed
Bathroom	Bathroom Cabinets - Damaged/Missing	Damaged or missing shelves, vanity tops, drawers, or doors that are not functioning as they should for storage or their intended purpose
	Lavatory Sink - Damaged/Missing	Sink, faucet, or accessories are missing, damaged, or not functioning
	Plumbing - Clogged Drains, Faucets	Drain or faucet is substantially or completely clogged or has suffered extensive deterioration
	Plumbing - Leaking Faucet/Pipes	A steady leak that is adversely affecting the surrounding area
	Shower/Tub - Damaged/Missing	Shower, tub, or components are damaged or missing
	Ventilation/Exhaust System – Absent/Inoperable	Exhaust fan is not functioning or window designed for ventilation does not open
	Water Closet/Toilet - Damaged/Clogged/Missing	Fixture elements--seat, flush handle, cover etc.--are missing or damaged or the toilet seat is cracked or has a broken hinge or toilet cannot be flushed
Call-for-Aid (if applicable)	Inoperable	The system does not function as it should
Ceiling	Bulging/Buckling/Leaking	Ceiling is bowed, deflected, sagging, or is no longer aligned horizontally
	Holes/Missing Tiles/Panels/Cracks	Ceiling surface has punctures that may or may not penetrate completely or panels or tiles are missing
	Peeling/Needs Paint	Paint is peeling, cracking, flaking, or otherwise deteriorated on ceilings in common areas
	Water Stains/Water Damage/Mold/Mildew	Evidence of water infiltration, mold, or mildew that may have been caused by saturation or surface failure
Doors	Damaged Frames/Threshold/Lintels/Trim	Any door that is not functioning or cannot be locked because of damage to the frame, threshold, lintel or trim
	Damaged Hardware/Locks	Any door that does not function as it should or cannot be locked because of damage to the door's hardware
	Damaged/Missing Screen/Storm/Security Door	Any screen door or storm door that is damaged or is missing screens or glass--shown by an empty frame or frames or any security door that is not functioning or is missing
	Damaged Surface - Holes/Paint/Rusting/Glass/Rotting	Any door that has a hole or holes greater than 1 inch in diameter, significant peeling/cracking/no paint or rust that affects the integrity of the door surface, or broken/missing glass
	Deteriorated/Missing Seals (Entry Only)	The seals/caulking is missing on any entry door, or they are so damaged that they do not function as they should
	Missing Door	Any door that is required for security (entry) or privacy (Bathroom) that is missing or any other unit door that is missing and is required for proper unit functionality
Electrical System	Blocked Access to Electrical Panel	One or more fixed items or items of sufficient size and weight impede access to the building system's electrical panel during an emergency
	Burnt Breakers	Carbon residue, melted breakers or arcing scars are evident
	Evidence of Leaks/Corrosion	Corrosion that affects the condition of the components that carry current or any stains or rust on the interior of electrical enclosures or any evidence of water leaks in the enclosure or hardware
	Frayed Wiring	Nicks, abrasion, or fraying of the insulation that exposes any conducting wire
	GFI - Inoperable	The GFI does not function
	Missing Breakers/Fuses	Open and/or exposed breaker port
	<i>*Missing Covers</i>	A cover is missing, which results in exposed visible electrical connections
Floors	Bulging/Buckling	Flooring that is bulging, buckling or sagging or a problem with alignment between flooring types
	Floor Covering Damage	Floor covering has stains, surface burns, cuts, holes, tears, loose areas or exposed seams
	Missing Flooring Tiles	Flooring or tile flooring that is missing
	Peeling/Needs Paint	Painted flooring that has peeling or missing paint
	Rot/Deteriorated Subfloor	Rotted or deteriorated subflooring
	Water Stains/Water Damage/Mold/Mildew	Evidence of water infiltration, mold, or mildew that may have been caused by saturation or surface failure
Health & Safety	Air Quality - Mold and/or Mildew Observed	Evidence of mold or mildew is observed that is substantial enough to pose a health risk
	Air Quality - Sewer Odor Detected	Detectable sewer odors that could pose a health risk if inhaled for prolonged periods

Multifamily Rehabilitation Standards Appendix A: Uniform Physical Condition Standards for Multifamily Housing Rehabilitation		
NOTE: Observable Deficiencies in <i>*Bold Italic</i> are considered life-threatening and must be addressed immediately, if the housing is occupied.		
Inspectable Item	Observable Deficiency	Type and Degree of Deficiency that must be addressed
	<i>*Air Quality - Propane/Natural Gas/Methane Gas Detected</i>	Detectable strong propane, natural gas or methane gas odors that could pose a risk of explosion/ fire and/or pose a health risk if inhaled
	<i>*Electrical Hazards - Exposed Wires/Open Panels</i>	Exposed bare wires or openings in electrical panels (capped wires do not pose a risk)
	<i>*Electrical Hazards - Water Leaks on/near Electrical Equipment</i>	Water leaking, puddling or ponding on or immediately near any electrical apparatus that could pose a risk of fire, electrocution or explosion
	<i>*Emergency Fire Exits - Emergency/Fire Exits Blocked/Unusable</i>	The exit cannot be used or exit is limited because a door or window is nailed shut, a lock is broken, panic hardware is chained, debris, storage, or other conditions block exit
	<i>*Emergency Fire Exits - Missing Exit Signs</i>	Exit signs that clearly identify all emergency exits are missing or there is no illumination in the area of the sign
	<i>*Flammable Materials - Improperly Stored</i>	Flammable materials are improperly stored, causing the potential risk of fire or explosion
	Garbage and Debris - Indoors	Too much garbage has gathered-more than the planned storage capacity or garbage has gathered in an area not sanctioned for staging or storing garbage or debris
	Garbage and Debris - Outdoors	Too much garbage has gathered-more than the planned storage capacity or garbage has gathered in an area not sanctioned for staging or storing garbage or debris
	Hazards - Other	General defects or hazards that pose risk of bodily injury
	Hazards - Sharp Edges	Physical defects that could cause cutting or breaking of human skin or other bodily harm
	Hazards - Tripping	Physical defects in walkways or other travelled area that poses a tripping risk
	Infestation - Insects	Evidence of infestation of insects-including roaches and ants-throughout a unit or room, especially in food preparation and storage areas
	Infestation - Rats/Mice/Vermin	Evidence of rats or mice--sightings, rat or mouse holes, or droppings
Hot Water Heater	<i>*Misaligned Chimney/Ventilation System</i>	Misalignment that may cause improper or dangerous venting of gases
	Inoperable Unit/Components	Hot water from hot water taps is no warmer than room temperature indicating hot water heater is not functioning properly
	Leaking Valves/Tanks/Pipes	Evidence of active water leaks from hot water heater or related components
	Pressure Relief Valve Missing	There is no pressure relief valve or pressure relief valve does not drain down to the floor
	Rust/Corrosion	Significant formations of metal oxides, flaking, or discoloration--or a pit or crevice
HVAC System	Convection/Radiant Heat System Covers Missing/Damaged	Cover is missing or substantially damaged, allowing contact with heating/surface elements or associated fans
	Inoperable	HVAC does not function. It does not provide the heating and cooling it should. The system does not respond when the controls are engaged
	Misaligned Chimney/Ventilation System	Misalignment that may cause improper or dangerous venting of gases
	Noisy/Vibrating/Leaking	HVAC system shows signs of abnormal vibrations, other noise, or leaks when engaged
	Rust/Corrosion	Deterioration from rust or corrosion on the HVAC system in the dwelling unit
Kitchen	Cabinets - Missing/Damaged	Cabinets are missing or the laminate is separating. This includes cases, boxes, or pieces of furniture with drawers, shelves, or doors--primarily used for storage--mounted on walls or floors
	Countertops - Missing/Damaged	Flat work surface in a kitchen often integral to lower cabinet space is missing or deteriorated or damaged below the laminate
	Dishwasher/Garbage Disposal - Inoperable	Dishwasher or garbage disposal does not operate as it should
	Plumbing - Clogged Drains	Drain is substantially or completely clogged or has suffered extensive deterioration
	Plumbing - Leaking Faucet/Pipes	A steady leak that is adversely affecting the surrounding area
	Range Hood/Exhaust Fans - Excessive Grease/Inoperable	Apparatus that draws out cooking exhaust does not function as it should and/or accumulation of dirt threatens the free passage of air
	Range/Stove - Missing/Damaged/Inoperable	One or more burners are not functioning or doors or drawers are impeded or on gas ranges pilot is out and/or flames are not distributed equally or oven not functioning
	Refrigerator-Missing/Damaged/Inoperable	Refrigerator is missing or does not cool adequately for the safe storage of food
	Sink - Damaged/Missing	Sink, faucet, or accessories are missing, damaged, or not functioning
Laundry Area (Room)	Dryer Vent - Missing/Damaged/Inoperable	Dryer vent is missing or it is not functioning because it is blocked. Dryer exhaust is not effectively vented to the outside
Lighting	Missing/Inoperable Fixture	Permanent light fixtures are missing or not functioning, and no other switched light source is functioning in the room
Outlets/Switches	Missing	An outlet or switch is missing
	<i>*Missing/Broken Cover Plates</i>	An outlet or switch has a broken cover plate over a junction box or the cover plate is missing
Patio/Porch/Balcony	Baluster/Side Railings Damaged	Damaged or missing balusters or side rails that limit the safe use of an area
Smoke Detector	<i>*Missing/Inoperable</i>	Smoke detector is missing or does not function as it should
Stairs	Broken/Damaged/Missing Steps	A step is missing or broken

Multifamily Rehabilitation Standards Appendix A: Uniform Physical Condition Standards for Multifamily Housing Rehabilitation

NOTE: Observable Deficiencies in **Bold Italic* are considered life-threatening and must be addressed immediately, if the housing is occupied.

Inspectable Item	Observable Deficiency	Type and Degree of Deficiency that must be addressed
	Broken/Missing Hand Railing	Hand rail is missing, damaged, loose or otherwise unusable
Walls	Bulging/Buckling	Wall is bowed, deflected, sagged, or is no longer vertically aligned
	Damaged	Punctures in the wall surface that may or may not penetrate completely
	Damaged/Deteriorated Trim	Cove molding, chair rail, base molding, or other decorative trim is damaged or has decayed
	Peeling/Needs Paint	Paint is peeling, cracking, flaking, or otherwise deteriorated
	Water Stains/Water Damage/Mold/Mildew	Evidence of water infiltration, mold, or mildew--or damage caused by saturation or surface failure
Windows	Cracked/Broken/Missing Panes	Missing or cracked panes of glass
	Damaged Window Sill	Sill is damaged enough to expose the inside of the surrounding walls and compromise its weather tightness
	Missing/Deteriorated Caulking/Seals/Glazing Compound	Caulking or seals that resists weather is missing or deteriorated
	Inoperable/Not Lockable	Window that is not functioning or cannot be secured because lock is broken
	Peeling/Needs Paint	Paint covering the window assembly or trim is cracking, flaking, or otherwise failing
	<i>*Security Bars Prevent Egress</i>	The ability to exit through the window is limited by security bars that do not function properly and, therefore, pose safety risks